



Attestato N° / Certificate N°: **007_16**
Data / Date: **09/03/2016**
Richiedente / Applicant: **Customers**
Prodotto o Serie / Product or Serie: **Gas Ball Valve models 6310, 6350 & 6450**

INSTALLATION, SERVICING AND USE INSTRUCTIONS **FOR GAS MANUAL BALL VALVES ACCORDING TO BS EN 331:2015**

INSTALLATION

The gas ball valves, models 6310, 6350 & 6450, may be installed for flow in any direction
Use standard practices when installing the valves
Make sure pipes are properly aligned before the valve is installed
When tightening the valve to the pipe apply a wrench to the end nearest to the pipe being worked.

SERVICING

Periodically observe the valve to be sure of proper performance
More frequent observations are recommended if the valve is operating under extreme conditions

USER INSTRUCTIONS (Operational data)

Female end connections : threaded to ISO 7/1 Rp
Male end connections : threaded to ISO 7/1 R
Working pressure : 0 – 5 bar max.
Operating temperature range : -20°C to + 80°C
Suitable gas families : 1st and 2nd (medium pressure) 3rd (low pressure)

WARNINGS:

Any deterioration or destruction of any part of the manually operated ball valve and closed bottom taper plug valve shall result in the need to replace the complete valve: alterations to any part of the complete valve shall result in the valve no longer being in compliance with the performance requirements of this document;
Ensure that the manually operated ball valves and closed bottom taper plug valve allows and adequate flow rate for its intended use;
All installations should be performed in accordance with existing local installation regulations and codes of practise where they exist;
It is imperative to follow the installation instructions of the manually operated ball valves and closed bottom taper plug valve manufacturer and of the appliance manufacturer, including those for the correct position of the connection point for the valve.

AIGNEP SPA
GRAZIANO BUGATTI
Managing Director

AIGNEP S.p.A. - Via Don G. Bazzoli, 34 - 25070 Bione (BS) Italy - Tel. +39-0365-896626 - Fax. +39-0365-896561
Società Unipersonale del Gruppo La San Marco di Francesco Bugatti & C. S.a.p.a.
C.F. 00808880173 – P.IVA 00579210980 – R.E.A. C.C.I.A.A. BS n. 210976 – Cap Soc. € 3.500.000 i.v.
Stabilimenti/Plant: Via Manzoni, 11 – 25070 BIONE (BS) Italy – Web site: <http://www.aignep.it> – email: aignep@aignep.it